

Certificate of Compliance

Certificate Number **20101020-E233523**
Report Reference **E233523, 2010 October 20**
Issue Date **2010 October 20**

Page 1 of 1



Issued to: **ARMATURENWERK ALTENBURG GMBH**

AM WEISSEN BERG 30
04600 ALTENBURG
GERMANY

*This is to certify that
representative samples of*

REFRIGERANT VALVES
Refrigerant Shut-off Valves
Model DN125


Have been investigated by Underwriters Laboratories Inc.® (UL) or any authorized licensee of UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 207 - Standard for Safety for Refrigerant-Containing Components and Accessories, Nonelectrical, Eighth Edition.
CSA C22.2 No. 140.3-09 - Canadian Standard for Refrigerant-containing components for use in electrical equipment.

Additional Information: See UL On-Line Certification Directory at www.UL.com for additional information.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:

 the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

William R. Carney

Director, North American Certification Programs

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://www.ul.com/global/eng/pages/corporate/contactus/>